

General Environmental Laboratories, Inc.

P.O. Box 21866
Hilton Head Island, SC 29925

Phone 843.208.2006
Fax 843.208.2006

121 Mead Road
Suite E
Hardeeville, SC 29927

REPORT OF ANALYSIS


Client: BEAUFORT COUNTY SCHOOLS
ATTN: ED MILLER
2900 MINK PT. BLVD
BEAUFORT, SC 29902

Report Number: 18-0072
Project Name: BEAUFORT COUNTY SCHOOL DISTRICT
Client Project Number: 217144
Sample Matrix: DRINKING WATER
Sampled By: JACK DEWITT (CLIENT)
Report Date: 02-21-2018

SAMPLE IDENTIFICATION	LAB SAMPLE ID	COLLECTION DATE AND TIME	DATE AND TIME RECEIVED
001 - Firehouse Men's Room 0.30	18-0072-1	02/01/18 07:30	02/01/18 12:34
002 - Firehouse Kitchen 3.1	18-0072-2	02/01/18 07:31	02/01/18 12:34
003 - MCRES Mechanical 110	18-0072-3	02/01/18 07:40	02/01/18 12:34

4/20 - 1.7, 5/16 - 0.87

Released by: _____


Sheila Patel
Director of Laboratory Operations

S.C. Laboratory Certification: 27553001

Sample Narrative
Report Number: 18-0072
Project Name: BSCD
Client Project Number: 217144

Comments:

Samples were received in good condition.
Sample were received outside of $<6^{\circ}\text{C}$ temperature requirements.
All samples were received within sample holding time for analysis.

Qualifier and Qualifier Description

G = Analyzed by SC Laboratory Certification: 98001.

General Environmental Laboratories, Inc.

P.O. Box 21866
Hilton Head Island, SC 29925

Phone 843.208.2006
Fax 843.208.2006

121 Mead Road
Suite E
Hardeeville, SC 29927

REPORT OF ANALYSIS

Lab Sample ID: 18-0072-1
Client Sample ID: 001 - Firehouse Men's Room
Sample Matrix: Drinking Water

Date/Time Collected: 02/01/2018 07:30
Date/Time Received: 02/01/2018 12:34

Analyte	Result	Unit	Qualifier	RL	MDL	Analyzed	Dil Fac
Lead	0.30	ug/L	G	0.30	0.060	02/09/18 11:37	1
Method: 200.8 – Metals (ICP/MS)							

Lab Sample ID: 18-0072-2
Client Sample ID: 002 - Firehouse Kitchen
Sample Matrix: Drinking Water

Date/Time Collected: 02/01/2018 07:31
Date/Time Received: 02/01/2018 12:34

Analyte	Result	Unit	Qualifier	RL	MDL	Analyzed	Dil Fac
Lead	3.1	ug/L	G	0.30	0.060	02/09/18 11:30	1
Method: 200.8 – Metals (ICP/MS)							

Lab Sample ID: 18-0072-3
Client Sample ID: 003 - MCRES Mechanical
Sample Matrix: Drinking Water

Date/Time Collected: 02/01/2018 07:40
Date/Time Received: 02/01/2018 12:34

Analyte	Result	Unit	Qualifier	RL	MDL	Analyzed	Dil Fac
Lead	110	ug/L	G	0.30	0.060	02/16/18 13:30	1
Method: 200.8 – Metals (ICP/MS)							

General Environmental Laboratories, Inc.

P.O. Box 21866
Hilton Head Island, SC 29925
Phone 843 208 2006 Fax 843 208 2006

CHAIN OF CUSTODY RECORD

PAGE OF

121 Mount Road, Suite F
Hardenville, SC 29927

18-072

217144 work order

Client: Ed Miller
Report Address: 2950 Mark Ant Blvd
Beaufort SC 29902
Phone No: 843-812-2200
Fax No:
Contact e-mail:

Invoice No: 217144
Invoice Address:
Attn: Jack Dewitt
Sampled by:
P.O. No:
Billing e-mail:

Preservation Used: 1 = None (cool <6°C); 2 = Na₂S₂O₅/Ice; 3 = H₂SO₄; 4 = HCl; 5 = HNO₃; 6 = Other
Container Type: P = Plastic; G = Glass

PRESERVATIVE

Analysis Required

Sample ID	Sample Description	Date Sampled	Time Sampled	No. of Containers	Container Type	Grab	Composite	Wastewater	Groundwater	Drinking Water	Other	Analysis Required
001	Firehouse Mens Room	2/1/18	7:30am	1	P	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5
002	Firehouse Kitchen	2/1/18	7:31am	1	P	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5
003	McAfee's Mechanical	2/1/18	7:40am	1	P	<input checked="" type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	5
<p>1. Relinquished By: <u>[Signature]</u> Date: <u>2/1/18</u> Time: <u>12:34pm</u></p> <p>2. Relinquished By: <u>[Signature]</u> Date: <u>2/1/18</u> Time: <u>12:34</u></p> <p>Comments: <u>Public Order</u></p> <p>Received on Ice (circle): <u>Yes</u> No Ice Pack</p> <p>Receipt Temp °C: <u>1-5</u></p>												

COMPLIANCE MONITORING YES NO
1) Regulatory From Regulatory
2) 24 hours At Risk
3) 5 days Unknown